



User manual Pressure regulator ZT300

Contents

6.1 Preparations for commissioning146.2 Procedure for commissioning147 Operation157.1 Exchanging the process gas source158 Maintenance, cleaning and repairs178.1 General information on maintenance178.2 Regular maintenance work and cleaning18	1	Intro	oduction	3
2.2 Misuse 4 2.3 Identification / label 4 2.4 Environment. 5 2.4.1 Temperatures 5 2.4.2 Degree of cleanliness 5 2.4.3 Emissions 5 3 Safety 6 3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel 9 4 Design and function 10 4.1 Design 10 4.1 Design 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2.1 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.2.1 Connecting the incoming and outgoing lines 13 5.2.1 Connecting the rocess gas source	2	Des	cription	4
2.3 Identification / label 4 2.4 Environment 5 2.4.1 Temperatures 5 2.4.2 Degree of cleanliness 5 2.4.3 Emissions 5 3 Safety 6 3.1 Basic information on the safety instructions 6 3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel. 9 4 Design and function 10 4.1 Design 10 4.1 Design 10 4.1 Design and function 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.3 Checking the armature 13 6 Commissioning 14 <t< td=""><th></th><td>2.1</td><td>Intended use</td><td>4</td></t<>		2.1	Intended use	4
2.4 Environment		2.2	Misuse	4
2.4.1 Temperatures. 5 2.4.2 Degree of cleanliness 5 2.4.3 Emissions 5 3 Safety 5 3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel. 9 4 Design and function 10 4.1 Design 10 4.1 Design 10 4.1 Design 10 4.2 Functional description 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.3 Checking the armature 13 5.3 Checking the armature 13 5.3 Checking the armature 14 6 Commissioning 14 6.1 P		2.3	Identification / label	4
2.4.2 Degree of cleanliness 5 2.4.3 Emissions 5 3 Safety 5 3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel 9 4 Design and function 10 4.1 Design 10 4.2 Functional description 11 4.3 Technical description 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Properation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance. 17 8.2 <t< th=""><th></th><th>2.4</th><th></th><th></th></t<>		2.4		
2.4.3 Emissions. 5 3 Safety 6 3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel. 9 4 Design and function 10 4.1 Design. 10 4.2 Functional description. 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.1 Preparations for commissioning 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19				
3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel 9 4 Design and function 10 4.1 Design 10 4.1 Design 10 4.2 Functional description 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.3 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.1 General information on maintenance 17				
3.1 Basic information on the safety instructions 6 3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel 9 4 Design and function 10 4.1 Design 10 4.1 Design 10 4.2 Functional description 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.3 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.1 General information on maintenance 17	3	Safe	etv	6
3.2 Safety instructions 7 3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel. 9 4 Design and function 10 4.1 Design. 10 4.2 Functional description 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.3 Checking the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.3 Procedure for commissioning 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 <th></th> <th></th> <th>•</th> <th></th>			•	
3.3 Emergencies and safety devices 9 3.4 Qualification of the operating and maintenance personnel 9 4 Design and function 10 4.1 Design 10 4.2 Functional description 11 4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.3 Poeration 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 19			•	
3.4 Qualification of the operating and maintenance personnel. 9 4 Design and function		3.3		
4.1 Design. 10 4.2 Functional description. 11 4.3 Technical data 12 4.4 Boundaries and interfaces. 12 5 Installation. 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning. 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.2 Procedure for commissioning 14 7.1 Exchanging the process gas source. 15 7.1 Exchanging the process gas source. 15 8 Maintenance, cleaning and repairs. 17 8.1 General information on maintenance. 17 8.2 Regular maintenance work and cleaning. 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20		3.4	Qualification of the operating and maintenance personnel	9
4.1 Design. 10 4.2 Functional description. 11 4.3 Technical data 12 4.4 Boundaries and interfaces. 12 5 Installation. 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning. 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 6.2 Procedure for commissioning 14 7.1 Exchanging the process gas source. 15 7.1 Exchanging the process gas source. 15 8 Maintenance, cleaning and repairs. 17 8.1 General information on maintenance. 17 8.2 Regular maintenance work and cleaning. 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20	4	Des	ign and function	10
4.3 Technical data 12 4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 7 Operation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21			-	
4.4 Boundaries and interfaces 12 5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 7 Operation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21		4.2	Functional description	11
5 Installation 13 5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 7 Operation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21		4.3	Technical data	12
5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 7 Operation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21		4.4	Boundaries and interfaces	12
5.1 General information 13 5.2 Installation work 13 5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 7 Operation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21	5	Inst	allation	13
5.2.1 Connecting the incoming and outgoing lines 13 5.3 Checking the armature 13 6 Commissioning 14 6.1 Preparations for commissioning 14 6.2 Procedure for commissioning 14 7 Operation 15 7.1 Exchanging the process gas source 15 8 Maintenance, cleaning and repairs 17 8.1 General information on maintenance 17 8.2 Regular maintenance work and cleaning 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21				
5.3 Checking the armature 13 6 Commissioning		5.2	Installation work	13
6 Commissioning			5.2.1 Connecting the incoming and outgoing lines	13
6.1Preparations for commissioning146.2Procedure for commissioning147Operation157.1Exchanging the process gas source158Maintenance, cleaning and repairs178.1General information on maintenance178.2Regular maintenance work and cleaning189Repair199.1General information on repair work199.2Troubleshooting and fault rectification2010Dismantling and disposal21		5.3	Checking the armature	13
6.2Procedure for commissioning147Operation	6	Con	nmissioning	14
7 Operation		6.1	Preparations for commissioning	14
7.1 Exchanging the process gas source158 Maintenance, cleaning and repairs178.1 General information on maintenance178.2 Regular maintenance work and cleaning189 Repair199.1 General information on repair work199.2 Troubleshooting and fault rectification2010 Dismantling and disposal21		6.2	Procedure for commissioning	14
8 Maintenance, cleaning and repairs	7	Оре	ration	15
8.1 General information on maintenance. 17 8.2 Regular maintenance work and cleaning. 18 9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21		7.1	Exchanging the process gas source	15
8.2 Regular maintenance work and cleaning.189 Repair199.1 General information on repair work199.2 Troubleshooting and fault rectification2010 Dismantling and disposal21	8	Maiı	ntenance, cleaning and repairs	17
9 Repair 19 9.1 General information on repair work 19 9.2 Troubleshooting and fault rectification 20 10 Dismantling and disposal 21		8.1	General information on maintenance	17
9.1 General information on repair work199.2 Troubleshooting and fault rectification2010 Dismantling and disposal21		8.2	Regular maintenance work and cleaning	18
9.1 General information on repair work199.2 Troubleshooting and fault rectification2010 Dismantling and disposal21	9	Rep	air	19
10 Dismantling and disposal 21				
10 Dismantling and disposal 21			·	
	10			
10.2 Returns				
10.3 Disposal				

1 Introduction

This user manual is the original user manual for the Pressure regulator ZT300 from Spectron Gas Control Systems GmbH, referred to as Spectron.

The user manual is intended to facilitate correct and safe operation for the operating firm, and to warn against misuse. It is intended for the qualified personnel and the operator of the facility.



Incorrect operation

Incorrect operation of the system, e.g. due to instruction errors, can lead to personal injury or damage to the system.

- a) Access to the user manual by the operating and maintenance personnel must be absolutely ensured at all times.
- b) A copy of the system documentation including the user manual must therefore be kept either on the system or in a suitable and accessible location.

This user manual contains information protected by copyright law. It must not be photocopied, reproduced, translated or copied onto data carriers, either in full or in part, without prior authorisation. Spectron retains all further rights.

2 Description

2.1 Intended use

The permissible gas types and pressure ranges are each specified on the label (see "Identification / label").

The equipment versions of the Pressure regulator without electrical components may be used in an explosion hazard zone as they do not have separate ignition sources (ignition hazard assessment according to DIN EN ISO 80079-36).

Pressure regulator with electrical components that are suitable for use in an explosion hazard zone are marked on the label according to EU Directive 2014/34/EU.

To be able to use the Pressure regulator as intended, all persons working with it must comply with the specifications of the relevant user manual.

The area in which hazards can occur when used as intended is the area around the Pressure regulator. The danger zone changes depending on the system status and use.

2.2 Misuse

Any improper use constitutes misuse. Pressure regulator may only be used for the specified gases and in the specified pressure range. Pressure regulator with electrical components without marking according to EU Directive 2014/34/EU may not be used in an explosion hazard zone.

Furthermore, the following operating conditions are regarded as misuse:

- Use for gases in their liquid phase
- Failure to carry out inspection and maintenance work
- Pressurisation in reverse (opposite to the flow direction)
- Operation with gases that are not specified on the label
- Operation outside the permissible technical limit values
- Failure to heed and comply with any applicable legal regulations and other provisions
- Non-observance of the user manual
- Failure to heed the information on the label and in the product data sheet

2.3 Identification / label

The label is located on the on the body of the Pressure regulator. The label provides the following details:

Details	Example	
Project number	PROJECT	
Article description	ZT300-300-ISO5154	
Inlet pressure P1	300 bar	
Outlet pressure P2	45 bar	
Gas type	GAS TYPE	

2.4 Environment

2.4.1 Temperatures

Normal temperatures expected in a production area are assumed when operating the system: -20°C to +60°C.

The air humidity must be below 60 % rel. humidity to prevent condensation. The operating temperature depends on the gas used.

2.4.2 Degree of cleanliness

Access to the system and to the escape and rescue routes must not be blocked.

The product should be kept clean (dust-free).

A suitable purge gas must be used, taking into account the quality and properties of the process gas.

Compressed air must be used for the control air at least class 5 according to ISO 8573-1.

2.4.3 Emissions

The A-rated sound pressure level does not exceed the value of 70 dB(A). It is not necessary to wear hearing protection.

The waste gas line or a burst disc line must not end in areas where the escaping process gas poses a hazard to persons or the environment.

Further emissions in the form of vibrations, radiation, vapours, dusts and waste water do not occur in the regular operation of the product.

3 Safety

3.1 Basic information on the safety instructions

The product complies with the recognised technical regulations. Nevertheless, knowledge of the media used and their dangers as well as basic knowledge of the pressure control panel are prerequisites for safe and accident-free operation.

The user manual must be read and understood by every user. Instruction must be documented in writing.

The safety instructions are to be regarded as a supplement to the applicable accident prevention regulations and laws. Existing accident prevention regulations and laws must be observed in all cases.



NOTICE

Hazards from the operating environment of the system can lead to injuries to persons.

- a) No changes may be made to the system which result in a change in function.
- b) It is not possible to outline and cover in this manual all hazards arising from the environment or unforeseeable operating conditions of the system.

In the Safety Instructions chapter:

- Users are informed regarding hazards, residual risks and measures for risk reduction.
- The presentation of the safety instructions and the symbols is explained.
- Basic safety instructions to be observed in general are listed. Specific safety instructions are listed in the relevant chapters.



DANGER indicates an imminent danger. If not avoided, death or extremely serious injuries will result.



A WARNING

WARNING indicates a potential imminent danger. If not avoided, death or serious injury could result.



CAUTION indicates a potentially imminent danger. If not avoided, minor or moderate injury could result.



NOTICE

NOTICE indicates a potentially harmful situation. If not avoided, the system or property in its vicinity could be damaged.

3.2 Safety instructions

The safety instructions are to be observed by all persons working on the system. The rules and regulations for accident prevention applicable to the place of use are to be observed. The instruction of the operating and maintenance personnel on system safety must be documented.

Please pay special attention to this chapter to avoid accidents.

All measures and specifications in the safety data sheets must be implemented and observed.



Gas leaks

If gas escapes on the product, contamination of persons, fires or explosions or the displacement of atmospheric oxygen can occur! Serious or fatal injuries are possible.

- a) Do not place pipelines and fittings under mechanical stress. Never use pipelines and components as climbing aid or to secure other parts!
- b) In the event of leaks, immediately secure the affected area!
- c) Smoking and naked flame are strictly prohibited!



Intended use

Operation of the product with gases other than those specified or outside the limits may result in dangerous reactions in the system. Incorrect use poses considerable risks to operating personnel and the environment!

- a) Only use the product for gases for which it was designed.
- b) Only use the product in the specified limit values for pressure and withdrawal quantity.
- c) Usage for another type of gas or outside the limit values is prohibited and constitutes misuse.



Defective product

A defect on the product can result in unforeseeable operating conditions. Persons may be injured.

- a) The product may only be operated in technically perfect condition in compliance with all chapters of the user manual.
- b) Environmental protection laws and safety regulations must be observed.



Displacement of atmospheric oxygen

In the event of inert gas leaks, displacement of atmospheric oxygen may occur. Danger of suffocation!

a) The operator must ensure adequate ventilation and airing in all rooms with gas installations and monitor the oxygen content.



Repairs

If the product is not used as intended, unpredictable operating conditions may occur. Serious personal injuries are possible.

- a) Repairs may not lead to a change in function. The system may not be tampered with or modified.
- b) Before each repair, the system must be depressurised and flushed through.
- c) Repairs are only permitted to be carried out by trained persons.



Incorrect operation

Incorrect operation of the system, e.g. due to instruction errors, can lead to personal injury or damage to the system.

- a) Access to the user manual by the operating and maintenance personnel must be absolutely ensured at all times.
- b) A copy of the system documentation including the user manual must therefore be kept either on the system or in a suitable and accessible location.



Working on the product

If an accident occurs when working on the product, there is a considerable risk of injury.

- a) Never work on the product unattended or unannounced.
- b) Observe the site safety rules and permission procedure.



Maintenance

Incorrect maintenance or maintenance work performed at the incorrect time can result in damage to the system or injury to persons.

- a) To avoid static charges, do not clean the product using dry cloths. Use damp cotton cloths.
- b) The maintenance intervals are to be specified by the system operator as part of its risk assessment.
- c) Observe the maintenance intervals and maintenance guidelines from the manufacturer and the applicable guidelines.
- d) Components may only be replaced by spare parts of the same design. The specifications of the component manufacturers must be complied with during installation.



Pressure relief lines

Discharge of hazardous media at the end of a pressure relief line or exhaust air line.

- a) Pressure relief lines may not end in areas where the escaping process gas poses a hazard to persons or the environment.
- b) The position of the pressure relief line must be carefully checked taking into account the material properties, main wind direction and other conditions.



NOTICE

Lighting

Incorrect switching actions or confusion can occur due to inadequate lighting. a) Ensure sufficient lighting in accordance with the statutory regulations.

3.3 Emergencies and safety devices

The operational local safety regulations of the system operator, such as the alarm plan, fire safety regulations and the escape and rescue plans, apply in all cases for the operation of the Pressure regulator.

When handling gases, all specifications from the safety data sheets must be followed. Local emergency services should be informed of the gases used at the site of the system.

In the event of mechanical damage, the product must be put into a safe operating condition.

3.4 Qualification of the operating and maintenance personnel

The intended user group is the system operator (user of the system) and the system maintenance personnel.

Every person working on the system must be familiar with the functions and dangers associated with the overall system. Instruction on the system is to be documented in writing.

Maintenance and repair work should only be carried out by specially trained personnel.

All operators, as well as personnel who regularly enter the area, must be trained on a minimum of the following topics:

- Alarm rules at the site and conduct in the event of malfunctions and leaks
- Basic functions of the product
- User manual
- System documentation incl. manufacturer documentation
- Position of the safety devices
- Safety data sheets on the process gas used
- Personal protective equipment

In addition, operators must have the requisite physical and mental skills to operate and maintain the equipment.

Persons who do not meet this requirement (e.g. visitors), must not remain alone in the overall system.

Operating personnel must use appropriate personal protective equipment for the activities to be performed and the associated environmental hazards. The operational instructions and the specifications of the employers' liability insurance associations and the safety data sheets must be complied with.

4 Design and function

4.1 Design




Illustration 1: Pressure regulator design ZT300

The design described is an example. The product design may vary depending on the configuration.

Item	Description	Short name	Connection
1	Inlet: Cylinder connection, screw or female thread		See data sheet or indi-
2	Outlet pressure gauge	PG P2	vidual configuration
3	Process gas connection		
4	Waste gas connection (pressure relief valve / over-pres- sure valve)	PRV	
5	Label		

4.2 Functional description




Illustration 2: P&ID ZT300

The intended use of the Pressure regulator ZT300 is pressure relief of a gas from an inlet pressure to a fixed or adjustable outlet pressure.

This pressure reduction is performed by the pressure regulator. It is equipped with a pressure gauge to show the outlet pressure. The outlet pressure on the pressure regulator is set to a fixed value and must not exceed the defined maximum value given on the label.

In the case of the single-stage pressure regulation present here, the set outlet pressure does not remain completely constant and instead rises slightly as the inlet pressure decreases (e.g. caused by a draining cylinder).

4.3 Technical data



NOTICE

The technical data can be taken from the data sheet for the relevant product. If this is not available, you can view and download it at www.spectron.de.

The maximum input and output pressures and the gas type are given on the identification or label.

4.4 Boundaries and interfaces

The scope of supply includes the product as described in the "Design" chapter. The transfer points to process gas, exhaust air and auxiliary media (incl. power supply) are the connections on the pressure control panel or product.

The following areas and functions have not been included in the scope of supply from Spectron:

- other systems, lines and installations of the overall system
- Process gas source
- Exhaust air (this applies in particular to foreseeable problems, e.g. failure of the exhaust air system)
- Supply of auxiliary media (compressed air, purge gas)
- Power supply
- Lighting
- Controller

5 Installation

5.1 General information



Injury or damage in the event of incorrect assembly or disassembly

Special steps are required for assembly and disassembly work on the product. Personal injuries and damage to the product are possible.

- a) Assembly and disassembly work may only be carried out by the installation engineer or appropriately skilled specialist companies and persons.
- b) The product is not permitted to be re-used following disassembly. All components must be disposed correctly.

Depending on the type of gas, different requirements apply to the installation space of gas supply systems. It is essential to observe the legal regulations and trade association regulations, and the information in the safety data sheets.

Familiarise yourself with the necessary work steps (see "Installation work [▶ 13]") and prepare the necessary tools.

5.2 Installation work

5.2.1 Connecting the incoming and outgoing lines

All lines must be connected in accordance with the applicable standards and specifications and tested with purge gas (pressure test and leak test). The specifications on dimensioning of the connections are described in the "Design" chapter.

- Connect the process gas input of the pressure regulator to the gas source or the process gas line. Do not use an adapter between the gas source valve and the cylinder or bundle connection of the pressure regulator!
 Observe the identification of the inputs (IN) and outputs (out) or the arrow for the flow direction.
- 2. Connect the process gas output of the pressure regulator to the process.
- 3. Connect the waste gas outlet of the pressure regulator to the waste gas lines, if necessary.

5.3 Checking the armature

Check all connections for leakage.

6 Commissioning

6.1 Preparations for commissioning

Purge the armature prior to initial commissioning! It is imperative to adhere to the direction of the gas flow when doing this! You must not purge counter to the usual direction of flow (from the tapping point to the process gas source), as this can flush debris resulting from the installation work, for example, back into the armature.

The connecting threads and connecting surfaces of the gas source valves as well as the sealing rings must be checked to ensure that they are in perfect condition.

Always turn shut-off valves as far as the stop when opening or closing them.

Valves and ball valves must always be moved slowly and by no means abruptly.

Make sure that:

- the fittings are marked for the corresponding gas type,
- all protective caps have been removed,
- the assembly has been correctly carried out and a pressure test has been performed,
- all ball valves and valves are closed (the red marking is visible in the handwheel window) and
- the pressure regulator has been depressurised (if possible),
- the on-site exhaust gas system (if present) is functional at all times and is in operation,
- all shut-off armatures are checked for loose connections and
- the controller (if fitted) is in operation.

6.2 Procedure for commissioning

Flushing in the entire line network to the consumer must be implemented via a waste gas valve on the process. To do this, refer to the system documentation for the consumer.

- 1. Close all valves and fully depressurise the pressure regulator by turning the anticlockwise as far as it will go.
- 2. Open the process gas source valve and, if necessary, the downstream valves. Ensure that the pressure regulator is not subjected to a pressure surge.
- 3. Slowly set the pressure regulator to the required outlet pressure. The process source pressure and the gas type properties are to be taken into account here.

During regular operation, the system will be in supply mode.

For interrupting the supply or decommissioning, close all valves and fully depressurise the pressure regulator by turning anti-clockwise as far as it will go.

7 Operation

7.1 Exchanging the process gas source



NOTICE

Penetration of ambient air into the system

Each time you change the cylinder, ambient air gets into the connecting parts of the system. To prevent the gas and the entire system from being contaminated, the connection must be purged before gas is drawn from the cylinder again. In the case of non-toxic, non-corrosive gases, this can be done by means of multiple pressure purges with process gas. In the case of corrosive or toxic gases or gases that are hazardous in some other way, purging must be carried out with inert gas.



Gas source exchange

If a gas source exchange is performed incorrectly, gas leakage and poisoning of persons may occur.

- a) The gas source exchange are to be carried out by trained specialist personnel and never unattended.
- b) A pressure test must be conducted after each gas source exchange.
- c) For each gas source exchange, a new seal suitable for the used gas is to be used.
- d) Wear the personal protective equipment prescribed in the risk assessment.

With each gas source exchange, check the port for leak-tightness. We strongly recommend replacing the gasket every time the gas source is exchanged. Always turn the shut-off valves slowly and as far as the stop when opening or closing them!

Removing the empty process gas source:

- 1. Close the process gas source valve.
- 2. Briefly open the venting valve or decrease the pressure via the process.
- 3. Ensure that the pressure gauges indicate 0 bar and thus that the pressure regulator is fully relieved.
- 4. Fully release the adjustable pressure regulator.
- 5. Disconnect the process gas source connection.
- 6. Mount the sealing nut on the gas source valve and protective cap on the process gas source.
- 7. Identify, secure and remove the empty process gas source.

Connecting the new process gas source:

- 1. Provide new process gas source, position in front of the bracket and secure using the safety chain.
- 2. Remove and retain the protective cap and screw plug.
- 3. Check the port thread and gasket; a new gasket must be used each time the gas source is exchanged.
- 4. Screw the process gas connection onto the gas source valve by hand and tighten it gastight with a spanner.

- 5. Open the process gas source valve, build up pressure, and close it again. Check using leak test spray whether the process gas port is leak-tight.
- 6. Slowly open the gas source valve.

The pressure regulator is ready for supply.

8 Maintenance, cleaning and repairs

8.1 General information on maintenance



Noise emission

When working on pressurised pneumatic supply, significant noise emission can occur. Acute and chronic loss of hearing may result.

- a) Never perform work on the pressurised pneumatic supply without hearing protection.
- b) Only replace the silencers when the supply is unpressurised.



Incorrect operation

Incorrect operation of the system, e.g. due to instruction errors, can lead to personal injury or damage to the system.

- a) Access to the user manual by the operating and maintenance personnel must be absolutely ensured at all times.
- b) A copy of the system documentation including the user manual must therefore be kept either on the system or in a suitable and accessible location.



Working on the product

If an accident occurs when working on the product, there is a considerable risk of injury.

- a) Never work on the product unattended or unannounced.
- b) Observe the site safety rules and permission procedure.



A WARNING

Maintenance

Incorrect maintenance or maintenance work performed at the incorrect time can result in damage to the system or injury to persons.

- a) To avoid static charges, do not clean the product using dry cloths. Use damp cotton cloths.
- b) The maintenance intervals are to be specified by the system operator as part of its risk assessment.
- c) Observe the maintenance intervals and maintenance guidelines from the manufacturer and the applicable guidelines.
- d) Components may only be replaced by spare parts of the same design. The specifications of the component manufacturers must be complied with during installation.



Injury or damage in the event of incorrect assembly or disassembly

Special steps are required for assembly and disassembly work on the product. Personal injuries and damage to the product are possible.

- a) Assembly and disassembly work may only be carried out by the installation engineer or appropriately skilled specialist companies and persons.
- b) The product is not permitted to be re-used following disassembly. All components must be disposed correctly.



NOTICE

Lighting

Incorrect switching actions or confusion can occur due to inadequate lighting.

a) Ensure sufficient lighting in accordance with the statutory regulations.

Correctly performed and timely maintenance increases the service life, ensures availability and helps to avoid undesirable downtimes. Depending on the gas type, the components are subject to different maintenance intervals. Observe the stipulations from the applicable directives.

Servicing and maintenance measures are only permitted to be carried out by competent specialist companies and persons.

Maintenance work should be documented by the operator. The documentation should indicate who carried out which work and when (proof of maintenance).

It is only permitted to use original spare parts or equivalent spare parts as well as suitable tools:

The recommended maintenance and test intervals are to be observed! (Also observe the manufacturer's documents)

The causes of possible defects are to be investigated, e.g. damage, unusual noises, overheating, etc.

Before beginning maintenance work, the pressure control panel must be purged (see "Interruptions to operation for more than 48 hours"). After completing the works, a re-commissioning process must be carried out (see "Commissioning [▶ 14]").

8.2 Regular maintenance work and cleaning

For components in which the tests reveal wear or even malfunctions, repairs or component replacement must be carried out by competent specialist companies and persons.

Components	Test	Interval
Filter	Replace filter	Replacement with insufficient flow rate
All	Visual inspection for corrosion, damage and correct fastening Func- tional test	At least annually and before each commissioning process
	Functional test	
	Leakage test	
Earthing	Visual inspection for damage and correct fastening	At least annually

The product should be cleaned on a regular basis. Heavy soiling can lead to malfunctions. Only clean the product as necessary using a damp, lint-free and clean cloth, without cleaning agent.

9 Repair

9.1 General information on repair work



Noise emission

When working on pressurised pneumatic supply, significant noise emission can occur. Acute and chronic loss of hearing may result.

- a) Never perform work on the pressurised pneumatic supply without hearing protection.
- b) Only replace the silencers when the supply is unpressurised.



Incorrect operation

Incorrect operation of the system, e.g. due to instruction errors, can lead to personal injury or damage to the system.

- a) Access to the user manual by the operating and maintenance personnel must be absolutely ensured at all times.
- b) A copy of the system documentation including the user manual must therefore be kept either on the system or in a suitable and accessible location.



Working on the product

If an accident occurs when working on the product, there is a considerable risk of injury.

- a) Never work on the product unattended or unannounced.
- b) Observe the site safety rules and permission procedure.



Injury or damage in the event of incorrect assembly or disassembly

Special steps are required for assembly and disassembly work on the product. Personal injuries and damage to the product are possible.

- a) Assembly and disassembly work may only be carried out by the installation engineer or appropriately skilled specialist companies and persons.
- b) The product is not permitted to be re-used following disassembly. All components must be disposed correctly.



NOTICE

Lighting

Incorrect switching actions or confusion can occur due to inadequate lighting. a) Ensure sufficient lighting in accordance with the statutory regulations.

The objectives of the repair are:

Detect and assess causes of malfunction

Rectify faults and restore operational readiness

Repairs to the product may only be performed by the manufacturer or specialist personnel instructed on the system.

Work on electrical system parts may only be performed by a qualified electrician.

Before beginning work, the pressure control panel must be purged (see "Flushing through to the process"). After completing the works, a re-commissioning process must be carried out (see "Commissioning [▶ 14]").

9.2 Troubleshooting and fault rectification

Fault	Possible cause	Remedy
		•
Outlet pressure too low	Process gas source empty	Check inlet pressure on the pressure regulator and change the process gas source if ne- cessary
Vibration noises in the pres- sure regulator	Pressure regulator faulty	Replace pressure regulator
Pressure regulator frozen	Flow rate too high	Reduce flow rate or use gas preheater if possible
System pressure cannot be set	Pressure regulator faulty	Replace pressure regulator
to the desired value	System pressure outside the intended system pressure	Only operate the system at the intended range
Flow insufficient or fluctuating	Inlet pressure of the process gas too low	Increase inlet pressure
	Valve faulty	Replace faulty valve
	Filter loaded	Change filter
Relief valve, over-pressure valve, safety valve or burst disc are discharging gas	Impermissible pressure rise in the outlet pressure range	Close all valves and check pressure control panel
HPI valve cannot be opened or	Pneumatic pressure too low	Check pneumatic pressure
closed	Compressed air hose ripped	Replace compressed air hose out
Leak	Connection leaking	Flush pressure control panel clear and perform pressure test and leak test

10 Dismantling and disposal

10.1 General information on dismantling



Noise emission

When working on pressurised pneumatic supply, significant noise emission can occur. Acute and chronic loss of hearing may result.

a) Never perform work on the pressurised pneumatic supply without hearing protection.

b) Only replace the silencers when the supply is unpressurised.



Injury or damage in the event of incorrect assembly or disassembly

Special steps are required for assembly and disassembly work on the product. Personal injuries and damage to the product are possible.

- a) Assembly and disassembly work may only be carried out by the installation engineer or appropriately skilled specialist companies and persons.
- b) The product is not permitted to be re-used following disassembly. All components must be disposed correctly.



NOTICE

Lighting

Incorrect switching actions or confusion can occur due to inadequate lighting.

a) Ensure sufficient lighting in accordance with the statutory regulations.

Before dismantling and disposal of the product, it must be taken out of operation and purged. The product must then be disconnected from the auxiliary media supply.

The dismantling process is to be carried out in the following order:

- 1. Purging of the product and decommissioning.
- 2. Disconnect the product from the gas supply system.
- 3. Disconnect the product from the process.
- 4. Remove the product to do so, please refer to the "Installation [▶ 13]" chapter.
- 5. Seal all ports on the product.
- 6. Pack the product.

10.2 Returns

If products are returned to Spectron for checking, maintenance or repair, it is essential to purge them with inert gas. A check can only be undertaken by Spectron if the repair pre-registration including the decontamination declaration has been duly completed.

10.3 Disposal

Dismantling and disposal must be carried out in accordance with the official and legal requirements at the site of the system. The operator must produce a risk assessment and work instructions before dismantling. A piece of equipment may only be disposed of when the decontamination declaration has been provided, completed in full.



Spectron Gas Control Systems GmbH Fritz-Klatte-Str. 8 D-65933 Frankfurt Tel: +49 (0)69 38016-0 Fax: +49 (0)69 38016-200 info@spectron.de www.spectron.de